

CITY OF CHANDLER FIRE NOTIFICATION SYSTEM PRE-TEST VERIFICATION

The City of Chandler requires ALL fire notification systems to be pre-tested before scheduling an inspection. This form must be filled out PRIOR to the inspector arriving on site and presented to inspector at the start of an inspection. Failure to comply with this requirement will result in a re-inspection fee and 48 hour re-scheduling delay.

NOTE: ALL Fire Inspections require 48 hour advance scheduling. Inspections must be first scheduled with inspector for a date and time and then scheduled through the automated Inspection scheduling system at 480-782-3100. Failure to comply with this requirement will result in the cancellation of the inspection.

Print or Type only. This form must be Legible to City Inspector
(One Document must be completed for EACH building on site)

Permit Information

City of Chandler Permit Number _____

Permit Issued To (Name of Contractor) _____

Contact Individual _____

Contact Individual Phone Number(s) _____

Building Location

Business Name _____

Address / Suite No. _____

Occupancy Type(s) _____ Building Type _____

Pre-Test Information

Date of Pre-test _____

Individual(s) Performing Pre-Test _____

Pre-Test Individual Phone Number(s) _____

Installation Contractor _____

Contractor Contact Individual _____

System Monitoring

Monitoring Company _____

Monitoring Company Phone Number _____

Pre-Test Affidavit

I (print name of individual performing pre-test) _____ certify that the required pre-test was performed on (date) _____ and that the system is installed in accordance and in compliance with approved plans/specifications.

Signature _____ Date _____

CITY OF CHANDLER FIRE NOTIFICATION SYSTEM PRE-TEST VERIFICATION

Type of Device(s)	Number of Devices	Location Per City		Performance Test Date
		Approved	Plans	
Fire Alarm Control Panel		Y	N	
Secondary Power Supply		Y	N	
Annunciator(s)		Y	N	
Sprinkler Water Flow Detectors		Y	N	
Tamper Switch / PIV		Y	N	
Fire Sprinkler Bell		Y	N	
Manual Pull Station		Y	N	
Area Smoke Detectors		Y	N	
Duct Smoke Detectors		Y	N	
Heat Detectors		Y	N	
Audible Notification Devices		Y	N	
Visual Notification Devices		Y	N	
Audible/ Visual Notification Devices		Y	N	
Kitchen Type I Hood Fire Extinguishing System		Y	N	
Fire Shutters		Y	N	
Delayed Action Egress Locks		Y	N	
Verify Correct Address With Monitoring Company		Y	N	
Verify Correct Time With Monitoring Company		Y	N	
Verify Signals With Monitoring Company		Y	N	
Other List Below		Y	N	
		Y	N	
		Y	N	